

**OFFICE OF THE DISTRICT MEDICAL & HEALTH OFFICER
RANGA REDDY DISTRICT.**

At Shivarampally, Rajendranagar, Hyderabad, Telangana State.

Rc.No.2758/D&O/DM&HO/RR/2025

Dated: 03 - 09-2025

SANITARY CERTIFICATE

I hereby declared that Health Inspector inspected the **M/s Sri Vamsihidhar High School, Located at Nadergul (Village), Balapur (Mandal), Ranga Reddy District.** Building premises and the accommodation provided for each of the several classes is sufficient for the maximum number of Pupils taught therein, and is properly ventilated and lighted, that the building is maintained is substantial repairs, that is neat and clean, that the urinals & latrine arrangements are adequate and satisfactory that the supply of drinking water is wholesome, and that in all other necessary respects the Hygienic and sanitation is good for the Academic year **2025-2026.**

This certificate should be got renewed starting of every academic year by applying to the District Medical & Health Officer, R.R. District.


District Medical & Health Officer,
Ranga Reddy District,
Dist. Medical & Health Officer
Ranga Reddy District.



Sree Mahendra

ANALYTICAL SERVICES PVT. LTD.

Genuine Quality Assurance

REGD.OFF:

1-7-292, Chaitanyapuri,

Opp: Geetha Hospital,

Hyderabad-500035.

Ph : 9133361333, 9133119119,8106559596

E Mail: mail2smasquality@gmail.com

Website: www.smaslabs.com


CERTIFICATE OF ANALYSIS

Job No:	22684B	Issued To: M/s. Sri Vamshidhar High School, Nadhargul, Balapur, Hyderabad.
Our Ref:	SMAS/W/002-09-014/25	
Reporting Date:	16.09.2025	
Collected On:	12.09.2025	
Sample Particulars:	BORE WATER	

TEST RESULTS

S.No	TEST PARAMETERS	UNITS	RESULTS	Desirable Potable Limits As Per IS: 10500-2012
PHYSICAL PARAMETERS:				
1.	p ^H	--	7.51	6.50 – 8.50
2.	Color	Hazen	Colorless	< 5
3.	EC	µmhos/cm	1573	Not Specified
CHEMICAL PARAMETERS:				
1.	Turbidity	NTU	0.20	< 1.0
2.	Total Dissolved Solids	mg/l	906	< 500
3.	Total Hardness as CaCO ₃	mg/l	460.0	< 200
4.	Non Carbonate Hardness as CaCO ₃	mg/l	Nil	Not Specified
5.	Calcium as Ca	mg/l	78.54	< 75
6.	Magnesium as Mg	mg/l	64.15	< 30
7.	Alkalinity to Phenolphthalein as CaCO ₃	mg/l	Nil	Not Specified
8.	Alkalinity to Methyl orange as CaCO ₃	mg/l	531.76	< 200
9.	Chlorides as Cl	mg/l	218.78	< 250
10.	Sodium as Na	mg/l	200.93	Not Specified
11.	Potassium as K	mg/l	5.06	Not Specified
12.	Sulphates as SO ₄	mg/l	70.14	< 200
13.	Nitrates as NO ₃	mg/l	2.55	< 45
14.	Silica as SiO ₂	mg/l	13.57	Not Specified
15.	Iron as Fe	mg/l	0.02	< 0.3
16.	Fluoride as F	mg/l	1.40	< 1.0
17.	Lead as Pb	mg/l	<0.01	< 0.01
MICROBIOLOGICAL PARAMETERS:				
1.	Total no. of Coliforms	MPN/100ml	01	NIL
2.	Total no. of E.coli	Cfu/100ml	Absent	Absent in 100ml
3.	Total bacterial Count	Cfu/ml	62 x 10 ¹	Not Specified

- Note:**
- The sample is analyzed as per IS: 3025 methods for Chemical analysis
 - The certificate relates only to the sample tested.
 - The above test results are not meeting the standards, hence the given water sample is not potable for drinking.



vashy
Chemist

Sree
Authorized Signatory



TS Govt. Regd. No. 591/12, Small Scale Industries Certified Laboratory
ISO 9001:2015, ISO 45001:2018, ISO 14001:2015 certified Laboratory

Save Trees - Save Environment

In the field of dedicated Analytical Services





Sree Mahendra

ANALYTICAL SERVICES PVT. LTD.

Genuine Quality Assurance

REGD.OFF:

1-7-292, Chaitanyapuri,

Opp: Geetha Hospital,

Hyderabad-500035.

Ph : 9133361333, 9133119119,8106559596

E Mail: mail2smasquality@gmail.com

Website: www.smaslabs.com

CERTIFICATE OF ANALYSIS


Job No:	22684A	Issued To: M/s. Sri Vamshidhar High School, Nadhargul, Balapur, Hyderabad.
Our Ref:	SMAS/W/002-09-013/25	
Reporting Date:	16.09.2025	
Collected On:	12.09.2025	
Sample Particulars:	RO DRINKING WATER	

TEST RESULTS

S.No	TEST PARAMETERS	UNITS	RESULTS	Desirable Potable Limits As Per IS: 10500-2012
PHYSICAL PARAMETERS:				
1.	pH	--	6.52	6.50 – 8.50
2.	Color	Hazen	Colorless	< 5
3.	EC	µmhos/cm	52.09	Not Specified
CHEMICAL PARAMETERS:				
1.	Turbidity	NTU	<0.01	< 1.0
2.	Total Dissolved Solids	mg/l	30	< 500
3.	Total Hardness as CaCO ₃	mg/l	08.00	< 200
4.	Non Carbonate Hardness as CaCO ₃	mg/l	Nil	Not Specified
5.	Calcium as Ca	mg/l	1.602	< 75
6.	Magnesium as Mg	mg/l	0.972	< 30
7.	Alkalinity to Phenolphthalein as CaCO ₃	mg/l	Nil	Not Specified
8.	Alkalinity to Methyl orange as CaCO ₃	mg/l	18.26	< 200
9.	Chlorides as Cl	mg/l	7.88	< 250
10.	Sodium as Na	mg/l	15.69	Not Specified
11.	Potassium as K	mg/l	0.31	Not Specified
12.	Sulphates as SO ₄	mg/l	<0.01	< 200
13.	Nitrates as NO ₃	mg/l	<0.01	< 45
14.	Silica as SiO ₂	mg/l	<0.01	Not Specified
15.	Iron as Fe	mg/l	<0.01	< 0.3
16.	Fluoride as F	mg/l	0.04	< 1.0
17.	Lead as Pb	mg/l	<0.01	< 0.01
MICROBIOLOGICAL PARAMETERS:				
1.	Total no. of Coliforms	MPN/100ml	Nil	NIL
2.	Total no. of E.coli	Cfu/100ml	Absent	Absent in 100ml
3.	Total bacterial Count	Cfu/ml	12	Not Specified

- Note:**
1. The sample is analyzed as per IS: 3025 methods for Chemical analysis
 2. The certificate relates only to the sample tested.
 3. The above test results are meeting the standards, hence the given water sample is potable for drinking.

Vasyl
Chemist



Sree
Authorized Signatory



TS Govt. Regd. No. 591/12, Small Scale Industries Certified Laboratory
ISO 9001:2015, ISO 45001:2018, ISO 14001:2015 certified Laboratory

Save Trees - Save Environment

In the field of dedicated Analytical Services

